

Republic Of Iraq

Ministry Of Oil

South Gas Company

E-Mail:south\_gascom@sgciraq.com

**SGC-M102-2011**

**EQUIPMENT USED AT DEHYDRATION**

ITEM	DESCRIPTION	UNIT	REQ QTY
	EQUIPMENT USED AT DEHYDRATION UNIT PHASE 1(REBOILER) AT ZUBAIR , NORTH AND SOUTH RUMAILA		
1	IGNATION SPARK PLUG(IGNATION ROD),HEAVY DUTY,HIGH VOLTAGE SUITABLE FOR GLYGOLE REBOILER SYSTEM , TYPE : OPERATION (6000V), AUBURN I-18 WITH FOLLOWING DIMENTIONS: X=40MM, Y=6MM, Z=29MM, M=40MM, R=192MM, W=315MM,  A=18.5MM, B=21MM , C=23MM , SEE FIG.(1)	NOS	50
2	IGNITION TRANSFORMER, 200 VA, 50HZ, 115V PRIMARY, 1 -6000V SECONDARY OUTPUT TERMINAL, IP55, AMB. TEMP. 55°C.	NOS	50
3	IGNITION TRANSFORMER, 200 VA, 50HZ, 220V PRIMARY, 1-6000V SECONDARY OUTPUT TERMINAL, IP55, AMB. TEMP. 55°C	NOS	50
4	HIGH TEMP. IGNITION CABLE (550°F), 7MM DIAMETER, (20, 000) VOLTS.	MTR	1000

**ORIGINS: U.K, FRANCE, FINLAND, GERMANY, ITALY, U.S.A .**