

## المواصفات الفنية

بنل تغذية كهربائية 11KV ,200 A عدد ٢ و بالمواصفات التالية : -

- TYPE NE –DI
- IP3X
- NON EXTENSIBLE
- BUSBAR RATING 200 A
- SWITCH - DISCONNECTOR 3- POSITION
- 200A DISCONNECTOR CB - 3-POSITION
- STANLESS STEEL TANK (INTERNAL ARC UP TO 20 KA 1s
- CABLE COMPARTMENTS
- MAIN EARTH COLLECTORAL
- CABLE CLAMPING
- OPERATING LEVER
- VIP 35 RELAY WITH TOROID
- O/C/EARTHED POSITION INDICATORS
- VISIBLE CLOSING OF EARTHING SWITCH (C)
- CIRCUIT BREAKER MOTOR MECHANISM(C)
- SWITCH – ON OPENING RELEASE
- CIRCUIT BREAKER POSITION (2Q +2C )
- EARTHING SWITCH POSITION (1 OC)
- FAULT INDICATION (1 OC)
- INTEGRATED CABLE TEST SESTEM
- SHORT – CIRCUIT BREAKING CAPACITY =21